

 **Corporate Office**

111 Wexford Road  
PO Box 14175  
Wellington New Zealand  
Telephone 04 385 5100  
Facsimile 04 385 5139

11 October 2000

Penny Race  
Opus International  
P O Box 12 003  
Wellington

Dear Penny

**MOA POINT SEWAGE TREATMENT PLANT**

I return the three consent applications signed by the Chief Executive.

Beca reviewed the applications on WIAL's behalf, and I enclose a copy of their findings.

You will see that they have no problem with the substance of the applications, hence WIAL is prepared to sign them in order to make progress.

However Beca has recommended three minor amendments to the conditions as marked on their letter.

- The amendments to condition 7 & 8 simply suggest that the contractor include the calibration reports in its reports to WRC
- The amendment to condition 6 requests that in the event an exceedance is measured, that there follows a period of monthly monitoring for six months, thereafter returning to the six month cycle.

WIAL's consent to the application is conditional on your acceptance of these conditions.

WIAL requests that at the time you lodge your application both this letter and the Beca attachment be included for WCC's consideration.


Yours sincerely



**David Gordon**

---

 **Terminal Office** Stewart Duff Drive Wellington Facsimile 64 04 385 5 137

 **Airport Fire Service** Stewart Duff Drive Wellington Facsimile 64 04 385 5136